

ADDENDUM NO. 1

TO: ALL BIDDERS OF RECORD

PROJECT: Steel Creek 2015 Fence

FWP PROJECT #: 16-03

DATE: September 30, 2015

FROM: Paul Valle, Montana FWP Project Manager

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

1. Rails shall be coped and attached to the Jack Legs.
2. Jack Legs shall be 5 "diameter minimum.
3. North end Steel Creek Fence is as shown on the attached Map Figure 1, rather than as discussed at the pre-bid meeting.

West Side Steel Creek Fence

